### **SPECIFICATIONS** (OS-1000-SS-CS3) 6" inlet/outlet connections, 4" vent connection. Max flow rate: 314 GPM 3. Liquid capacity: 1000 Gallons (133.7 cu. ft.); Oil: 736 gal.; Sand: 35 gal. 26" -26" 4. Unit weight w/std. covers: 1500 lbs. 5. Highway traffic load rated, bolted, gas/water tight composite covers. (16,000 lbs) Maximum operating temperature 140°F continuous. 4" Vent 7. Slick Stick™ Oil Monitoring System (see page 2). **NOTES** 1. 1" thick high density polyethylene walls. 2. Unit supplied with built-in adapter(s) for up to 3-1/2" of Ø 68" adjustability. Additional riser(s) available for deeper burial depth. 3. For buried applications. 4. Lifting lug set included for easy install. **ENGINEER SPECIFICATION GUIDE** Striem oil separator model OS-1000-SS-CS3 shall be lifetime guaranteed and made in USA of High Density Polyethylene with minimum 1" -Adjustable adapters-Reinforced uniform wall thickness. Separator shall be furnished for below grade installation with bolted and gasketed end walls with field adjustable riser system. Separator shall be furnished with an oil level highway rated composite covers monitoring system. Separator flow rate shall be 314 GPM. Separator oil Stabilizing feet capacity shall be 736 gallons. Sand capacity shall be 35 gallons. Cover shall Control panel-**ISOMETRIC VIEW** provide water/gas-tight seal and have a maximum 16,000 lbs load capacity. **TOP VIEW THIRD PARTY STRUCTURAL ANALYSIS** Closed top outlet The OS-1000-SS-CS3 has been structurally analyzed in accordance with the requirements of IBC 2012 and ASCE/SEI 7 for direct burial. diptube to provide 90" Finished grade Lifting Lug The maximum burial depth and backfill material are specified in our sewer gas trap with installation instructions. The structural design has been reviewed and 76" Inside 4" cleanout See options to sealed by a professional engineer registered in the state of California. 4" Vent determine available Ø 24-1/2" A sealed structural analysis report is available upon request. dimension range € of 6" outlet Q of 6" inlet-**OPTIONS** TYP 4M - 4" Male Thread Inlet / Outlet PVC extension 4P - 4" Plain End Inlet / Outlet 50' of 21" by others **6M** - 6" Male Thread Inlet / Outlet cable included **8P** - 8" Plain End Inlet / Outlet C24-HP (2) - H20 Rated Pickable Cast Iron Covers **HDK-1** - High Water Table Hold Down Kit 80" **TeleGlide RISER OPTIONS SR24** (2) - >3-1/2"-22" 59" Static **LR24** (2) - >22"-37" water **SR24** (4) - >37"-41" Ø 66" line **SR24** (2) + **LR24** (2) - >41"-56" Inside 14" Typ **LR24** (4) - >56"-70" Clean Sweep™ polypropylene coalescing media has been Interface float to third party tested to performance standard CEN EN858-1 6" Typ — B◀ detect oil level for class 1 coalescing separators. Baffle PO IS NON-CANCELABLE **SECTION A-A SECTION B-B** Removable Coalescing Media— ORDER IS NON-RETURNABLE MODEL NUMBER: OS-1000-SS-CS3

Signature of Approval: Company: \_\_\_\_\_ Date of Approval: \_\_\_\_\_ Specifying Engineer: \_\_\_\_\_ Engineering Firm:

PROPRIETARY AND CONFIDENTIAL

1000 GAL POLYETHYLENE OIL/SAND SEPARATOR WITH CLEAN SWEEP™ COALESCING MEDIA AND SLICK STICK™ OIL LEVEL MONITORING SYSTEM

**DWG BY:** MJ

**DESCRIPTION:** 

**DATE**: 06/29/2020 | **REV**: 02 | **ECO**:

# SPECIFICATION SHEET

**Striem** 3100 Brinkerhoff Kansas City, KS 66115 Tel: 913-222-1500 Fax: 913-291-0457 www.striemco.com

Made in the U.S.A





THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF **STRIEM**, **LLC**. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF **STRIEM**, **LLC**. IS PROHIBITED.

# **SPECIFICATIONS**


- 1. UL Listed

- Provides warning of high oil level conditions with interface float.
   Single phase, 120 volt, 60 hertz power required.
   NEMA 4X fiberglass, corrosion resistant, weatherproof enclosure suitable for outdoor use and damp environments.
- 5. Audible Alarm Buzzer, 95dB pulsing horn with no timeout.6. High Oil Light, indicates oil has accumulated below the oil interface float or the tank liquid level is below the High Oil Interface Float.
  7. Power On light inside enclosure. Visible from the outside.
- Green light indicates the power is on.
- 8. Horn off button that silences the audible alarm when pressed.
- 9. Test button that when pressed will test the system electronics.
- 10. Locking clasp on door.
- 11. Alarm bell stays on until reset. Light stays on until reset, even if level goes down.
- 12. Unit comes supplied with extra dry contact for connection to a building alarm system.






**FRONT VIEW** 



**LEFT VIEW** 



# **BOTTOM VIEW**

**MODEL NUMBER:** 8056-001-01

## **DESCRIPTION:**

SLICK STICK™ OIL LEVEL MONITORING SYSTEM FOR OS-50, OS-75, OS-100, OS-750, OS-1000 & OS-1500

**DWG BY:** MJ

**DATE:** 06/29/2020 **REV:** 02 **ECO:** 

# SPECIFICATION SHEET

**Striem** 3100 Brinkerhoff Kansas City, KS 66115 Tel: 913-222-1500 Fax: 913-291-0457 www.striemco.com

Made in the U.S.A



## **Installation Guidelines:**

- 1. The Slick Stick™ interface float and alarm panel will ship separately from the tank.
- 2. Install the 1/2" FPT brass coupling to the end of the Slick Stick™ interface float. Thread the 1/2" MPT x socket PVC fitting into the 1/2" FPT brass coupling.
- socket PVC fitting into the 1/2" FPT brass coupling.

  3. If the tank is to be installed above grade, or without any adjustment to the adapter, install a length of 1/2" sch. 40 PVC pipe between the bottom of the junction box and the top of the 1/2" MPT x socket PVC fitting. Choose the length from Table 1 that corresponds with the unit, and oil capacity to be monitored.
- 4. If the tank is buried, and the adapter will be adjusted upward and/or risers will be used, add the total upward extension dimension to the length determined from Table 1 to determine total length of 1/2" PVC pipe length. For example, assume an OS-75 is being installed below grade and requires 26" of riser extension. Assume you want the control panel to alarm when the oil capacity reaches 70% of the total oil capacity. The length of the 1/2" PVC pipe extension should be 26" (riser depth) + 10" (from Table 1) = 36".
- 5. Run interface float wiring through 1/2" PVC pipe and into the bottom of the juntion box inside the adapter. Connect wiring to alarm panel (see wire diagram).




Table 1: 1/2" PVC Pipe Length

Oil Capacity	OS-50	OS-75	OS-100	OS-750	OS-1000	OS-1500
50%	1-1/2"	6-5/8"	9-5/8"	15-3/4"	15-3/4"	15-3/4"
60%	2-3/8"	8-1/4"	11-1/2"	18"	18"	18"
70%	3-3/8"	10"	13-1/4"	20-1/4"	20-1/4"	20-1/4"
80%	4-3/8"	12"	15"	22-1/2"	22-1/2"	22-1/2"
90%	5-1/2"	13-7/8"	18-3/4"	24-1/2"	24-1/2"	24-1/2"

**DESCRIPTION:** 

DWG BY: MJ

SLICK STICK™
INTERFACE FLOAT
INSTALLATION GUIDELINES

**DATE:** 06/29/2020 | **REV:** 02 | **ECO:** 

Made in the U.S.A

Striem
3100 Brinkerhoff
Kansas City, KS 66115
Tel: 913-222-1500
Fax: 913-291-0457
www.striemco.com