Directions: Complete steps 1-3 and submit signed **SPECIFICATIONS** (OS-1500-SS-CS3) **FLOW** with purchase order. Max flow rate: 314 GPM 2. Max flow rate to achieve 5 ppm of residual light liquid in effluent: 45 GPM 1. Choose Connection Types Liquid capacity: 1500 Gallons (200.5 cu. ft.) 120" Size Inlet / Outlet Oil capacity: 1035 Gallons 68" 26" 26" Solids/sediment capacity: 35 Gallons Plain End Unit weight w/std. covers: 1350 lbs. **6**" Male Thread 7. Highway traffic load rated, bolted, gas/water tight 8" (Only Plain End composite covers. (16,000 lbs) -Vent 8. Maximum operating temperature 140°F continuous. Available) Slick Stick™ Oil Monitoring System (see page 2). Α **NOTES** Vent Size 1. 7/8" thick high density polyethylene walls. Ø68" Plain End 2. Unit supplied with built-in adapter(s) for up to 3-1/2" of adjustability. Additional riser(s) available for deeper **3**" burial depth. 4" 3. For buried applications. 4. Lifting lug set included for easy install. **ENGINEER SPECIFICATION GUIDE** 2. Riser Options Striem oil separator model OS-1500-SS-CS3 shall be lifetime guaranteed Included : 0" - 3-1/2" -Adjustable adapters and made in USA of polyethylene with minimum 7/8" uniform wall with bolted and gasketed **SR24** (2) - >3-1/2"-21-1/2" thickness. Separator shall be furnished for below grade installation with highway rated composite covers field adjustable riser system. Separator shall be furnished with an oil level **LR24** (2) - >21-1/2"-36-1/2" monitoring system. Separator flow rate shall be 314 GPM. Separator oil **SR24** (4) - >36-1/2"-40-1/2" **TOP VIEW** capacity shall be 1035 gallons. Sand capacity shall be 35 gallons. Cover **SR24** (2) + **LR24** (2) - >40-1/2"-55-1/2" shall provide water/gas-tight seal and have a maximum 16,000 lbs load **LR24** (4) - >55-1/2"-69-1/2" capacity. Control panel **SR24** (2) + **LR24** (4) : >69-1/2" - 87-1/2" THIRD PARTY STRUCTURAL ANALYSIS **LR24** (6): >87-1/2" - 103-1/2" 50' of The OS-1500-SS-CS3 has been structurally analyzed in accordance cable with the requirements of IBC 2012 and ASCE/SEI 7 for direct burial. 3. Choose Additional Options The maximum burial depth and backfill material are specified in our -included Finished Grade installation instructions. The structural design has been reviewed C24-HP (2) - H20 Rated Pickable Cast Iron Covers and sealed by a professional engineer registered in the state of **HDK-1** - High Water Table Hold Down Kit California. A sealed structural analysis report is available upon See options to Lifting Lug-Ø 24-1/2" _| determine available request. **TYP** ♠ of outlet dimension range **Q** of inlet-Reinforced 20-1/2" 22-1/2" end walls 20" Water Seal 79-1/2" **Static** water 59" line Closed top outlet diptube to provide sewer gas trap with 4" cleanout 106" Inside -Interface float to Removable Coalescing detect oil level **SECTION A-A** Stabilizing feet Media SPECIFICATION SHEET MODEL NUMBER: OS-1500-SS-CS3 Signature of Approval: Company: ____ **DESCRIPTION:** PO IS NON-**Striem CANCELABLE** Date of Approval: 3100 Brinkerhoff 1500 GAL POLYETHYLENE OIL/SAND SEPARATOR ORDER IS NON-Kansas City, KS 66115 WITH CLEAN SWEEP™ COALESCING MEDIA Specifying Engineer: _____ RETURNABLE Tel: 913-222-1500

DWG BY: MJ

AND SLICK STICK™ OIL LEVEL

MONITORING SYSTEM

DATE: 12/11/2020 | **REV:** 02 | **ECO:**

orders@striemco.com

www.striemco.com

Made in the U.S.A

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF **STRIEM**, **LLC**. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF **STRIEM**, **LLC**. IS PROHIBITED.


Engineering Firm: _____


PROPRIETARY AND CONFIDENTIAL

SPECIFICATIONS


- 1. UL Listed

- Provides warning of high oil level conditions with interface float.
 Single phase, 120 volt, 60 hertz power required.
 NEMA 4X fiberglass, corrosion resistant, weatherproof enclosure suitable for outdoor use and damp environments.
- 5. Audible Alarm Buzzer, 95dB pulsing horn with no timeout.
- 6. High Oil Light, indicates oil has accumulated below the oil interface float or the tank liquid level is below the High Oil Interface Float.
 7. Power On light inside enclosure. Visible from the outside.
- Green light indicates the power is on.
- 8. Horn off button that silences the audible alarm when pressed.
- 9. Test button that when pressed will test the system electronics.
- 10. Locking clasp on door.
- 11. Alarm bell stays on until reset. Light stays on until reset, even if level goes down.
- 12. Unit comes supplied with extra dry contact for connection to a building alarm system.










LEFT VIEW



BOTTOM VIEW

MODEL NUMBER: 8056-001-01

DESCRIPTION:

SLICK STICK™ OIL LEVEL MONITORING SYSTEM FOR OS-50, OS-75, OS-100, OS-750, OS-1000 & OS-1500

DATE: 12/11/2020 **REV:** 02 **ECO: DWG BY:** MJ

SPECIFICATION SHEET

Striem 3100 Brinkerhoff Kansas City, KS 66115 Tel: 913-222-1500 orders@striemco.com www.striemco.com

Made in the U.S.A



Installation Guidelines:

- 1. The Slick Stick™ interface float and alarm panel will ship separately from the tank.
- 2. Install the 1/2" FPT brass coupling to the end of the Slick Stick™ interface float. Thread the 1/2" MPT x socket PVC fitting into the 1/2" FPT brass coupling.

 3. If the tank is to be installed above grade, or without
- any adjustment to the adapter, install a length of 1/2" sch. 40 PVC pipe between the bottom of the junction box and the top of the 1/2" MPT x socket PVC fitting. Choose the length from Table 1 that corresponds with the unit, and oil capacity to be monitored.
- If the tank is buried, and the adapter will be adjusted upward and/or risers will be used, add the total upward extension dimension to the length determined from Table 1 to determine total length of 1/2" PVC pipe length. For example, assume an OS-75 is being installed below grade and requires 26" of riser extension. Assume you want the control panel to alarm when the oil capacity reaches 70% of the total oil capacity. The length of the 1/2" PVC pipe extension should be 26" (riser depth) + 10" (from Table 1) = 36".
- 5. Run interface float wiring through 1/2" PVC pipe and into the bottom of the juntion box inside the adapter. Connect wiring to alarm panel (see wire diagram).




Table 1: 1/2" PVC Pipe Length

Oil Capacity	OS-50	OS-75	OS-100	OS-750	OS-1000	OS-1500
50%	1-1/2"	6-5/8"	9-5/8"	15-3/4"	15-3/4"	15-3/4"
60%	2-3/8"	8-1/4"	11-1/2"	18"	18"	18"
70%	3-3/8"	10"	13-1/4"	20-1/4"	20-1/4"	20-1/4"
80%	4-3/8"	12"	15"	22-1/2"	22-1/2"	22-1/2"
90%	5-1/2"	13-7/8"	18-3/4"	24-1/2"	24-1/2"	24-1/2"

DESCRIPTION:

DWG BY: MJ

SLICK STICK™ **INTERFACE FLOAT INSTALLATION GUIDELINES**

| DATE: 12/11/2020 | REV: 02 | ECO:

Made in the U.S.A

Striem 3100 Brinkerhoff Kansas City, KS 66115 Tel: 913-222-1500 orders@striemco.com www.striemco.com



THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF **STRIEM**, **LLC**. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF **STRIEM**, **LLC**. IS